

scheme CESI - LV

certificate OF TYPE CONFORMITY WITH THE STANDARDS

standards CEI EN 60439-1 (1998-04) and CEI EN 60439-2 (1997-09)
IEC 60439-1 (1999-09) and IEC 439-2 (1987)

product Three-phase with neutral bar low-voltage busbar trunking system (busway).

designation **KBC 4010**

rated insulation voltage: 1000 V rated current: 4000 A rated frequency: 50 Hz

identification of the samples EAE packing list n. 172/29518252 (invoice n. 990148) dated September 1st, 1999
EAE packing list n. 172/35714022 (invoice n. 89168) dated September 24th, 1999

applicant **EAE ELEKTRIK A.S. - Istanbul (TURKEY)**

note : This certificate replaces the Certificate of Conformity CESI CERT - A0/025427 issued on July 28th, 2000.

This certificate attests that the product conforms with all the requirements of the above standards corresponding to the ratings and operating conditions assigned by the applicant as listed on page 2.

The product, constructed in accordance with the relevant description, drawings and photographs, has been subjected to the type tests in accordance with the above standards.


This certificate applies only to the samples identified; the responsibility for declaring the conformity of other products having the same designation with those certified rests with the applicant.

Only integral reproduction of this document is permitted without written permission from CESI.

n. of pages 7

issue date October 26th, 2000 - traslation issued on October 26th, 2000

prepared CERT - F. Zucchetti



approved CERT - U. Colombo

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Responsabile Area Certificazione



Registraz. n° 018B

The mark indicates that this Certificate is issued according to SINCERT accreditation No. 018B.